



# Mount Olive Township School District

*"Children are our first priority"*

**Larrie Reynolds, Ed.D.**  
**Superintendent of Schools**

(973) 691-4008 Extension 8100, [lreynolds@mtoliveboe.org](mailto:lreynolds@mtoliveboe.org)  
227 US Route 206, Suite 10, Flanders, NJ 07836

Nov. 8, 2017

All:

The results of our **second retest** for lead contaminants in water were released yesterday, Nov. 7. While the district is making progress in rooting out the source of lead and remediating it, we have not yet satisfied state standards with a number of fixtures. As a result, we are moving to intensity level three in remediating this issue. This new higher level of intensity means that some or all of the faucets will be permanently closed or completely replaced. **It should be noted that all of the faucets listed below have already been turned off or designated not for drinking already (since the first finding in August). Consequently, there has been no danger to anyone in the schools, students or staff.**

### Progress since last retest (end of September)

| School        | Faucets failed 1 <sup>st</sup> retest | Facets failed 2 <sup>nd</sup> retest |
|---------------|---------------------------------------|--------------------------------------|
| CMS           | 21                                    | 14                                   |
| MOHS          | 8                                     | 3                                    |
| MOMS          | 8                                     | 2                                    |
| Mountain View | 9                                     | 7                                    |
| Sandshore     | 1                                     | 0                                    |
| Tinc Road     | 16                                    | 2                                    |

### Failed listing Nov. 7

#### Mountain View Elementary

| ID         | Location      | Outlet Type | Result (ppb) |
|------------|---------------|-------------|--------------|
| MVE-SF-K1T | Kitchen-1 Tub | Sink Faucet | 42.0         |

|            |     |              |      |
|------------|-----|--------------|------|
| MVE-SB-128 | 128 | Sink Bubbler | 37.2 |
| MVE-SF-128 | 128 | Sink Faucet  | 57.6 |
| MVE-SF-115 | 115 | Sink Faucet  | 72.5 |
| MVE-SB-116 | 116 | Sink Bubbler | 16.2 |
| MVE-SF-116 | 116 | Sink Faucet  | 103  |
| MVE-SF-103 | 103 | Sink Faucet  | 34.0 |

Chester Stephens Elementary

| <b>ID</b>    | <b>Location</b>    | <b>Outlet Type</b>     | <b>Result (ppb)</b> |
|--------------|--------------------|------------------------|---------------------|
| CMS-SF-D66   | Rm D66             | Sink Faucet            | 495                 |
| CMS-DW-HCAFE | Hall at Café       | Drinking Water Bubbler | 38.0                |
| CMS-SF-K1T   | Kitchen-1 Tub Prep | Sink Faucet            | 29.0                |
| CMS-SF-HA4   | Hall at A-4        | Sink Faucet            | 24.2                |
| CMS-DW-HA25  | Hall at A25        | Drinking Water Bubbler | 115                 |
| CMS-SB-B27   | Rm B27             | Sink Bubbler           | 35.8                |
| CMS-SB-B38   | Rm B38             | Sink Bubbler           | 18.1                |
| CMS-SB-B28   | Rm B28             | Sink Bubbler           | 35.2                |
| CMS-SB-B29   | Rm B29             | Sink Bubbler           | 19.2                |
| CMS-SF-B19   | Rm B29             | Sink Faucet            | 153                 |
| CMS-SF-C44   | C44-Music Rm       | Sink Faucet            | 2760                |
| CMS-SF-C48   | Rm C48             | Sink Faucet            | 390                 |
| CMS-SF-C54   | Rm C54             | Sink Faucet            | 490                 |
| CMS-SF-C52   | Rm C52             | Sink Faucet            | 76.5                |

Tinc Rd. Elementary

| <b>ID</b>   | <b>Location</b>  | <b>Outlet Type</b> | <b>Result (ppb)</b> |
|-------------|------------------|--------------------|---------------------|
| TRE-SF-HAND | Kitchen-Handwash | Sink Faucet        | 15.8                |
| TRE-SB-146  | 146              | Sink Bubbler       | 26.2                |

Mt. Olive Middle

| <b>ID</b>       | <b>Location</b>            | <b>Outlet Type</b> | <b>Result (ppb)</b> |
|-----------------|----------------------------|--------------------|---------------------|
| MOM-FO-K        | Kitchen-Kettle             | Faucet Outlet      | 25.0                |
| MOM-SF-K1T-LONG | Kitchen-1 Tub Long<br>Prep | Sink Faucet        | 22.4                |

Mt. Olive High School

| <b>ID</b>    | <b>Location</b>        | <b>Outlet Type</b>     | <b>Result (ppb)</b> |
|--------------|------------------------|------------------------|---------------------|
| MHS-SF-B21   | B21-Fitness Rm         | Sink Faucet            | 192                 |
| MHS-SF-SNACK | Serving Area Snack Bar | Sink Faucet            | 31.5                |
| MHS-DW-GIRLS | Girl's Locker Room     | Drinking Water Bubbler | 57.6                |